SHEET NOTES

1. PROVIDE TRANSITION TO FUME HOOD COLLAR AS REQUIRED.
2. PROVIDE FLANGED CONNECTION FOR GALVANIZED DUCT TO STAINLESS STEEL DUCT.
3. CAP DUCTWORK AFTER VOLUME DAMPER.
4. REBALANCE DIFFUSER TO (N) CFM AS REQUIRED.

PARTAIL SECOND FLOOR – MECHANICAL PLAN (CENTER)
1/4"=1'-0"

1

NORTH

Gicklhorn Lazzarotto Partners

645 HARRISON ST
SUITE 101
SAN FRANCISCO
CA 94107

415 512 7795 T
415 512 7796 F

GLPsf.com

CONSULTANTS

MECHANICAL/ELECTRICAL/
PLUMBING ENGINEER
GAYNER ENGINEERS
1133 POST STREET
SAN FRANCISCO, CA 94109
TEL: 415.474.9500
FAX: 415.474.1363

KEY PLAN:

FIRE MARSHAL:

DSA:

University of California
Physical Planning and Construction
Santa Cruz Campus
Santa Cruz, California

Baskin Alterations - Labs 206, 207 & 208 Final User Build-out
Baskin Engineering Building
1156 High Street
Santa Cruz, CA 95064
UCSC PROJECT & FILE NO: 2700-111

ISSUE DATE

REVISIONS

NO.	DATE	DESCRIPTION
	10/19/07	ISSUED FOR FINAL REVIEW

PROJECT NO: 0723
CAD DWG FILE:
DRAWN BY:
CHECKED BY:
SHEET TITLE

PARTIAL SECOND FLOOR MECHANICAL PLAN (CENTER)

M-402-2

SHEET OF